



Evolution of Magnetic Flowmeters

Technological Innovation Makes a Proven Meter Type More Useful

Magnetic flowmeters have emerged as an extremely popular method of flow measurement for a number of reasons, but most importantly because they excel in measuring most kinds of liquids. They are also relatively cost-efficient and straightforward to install. Further, with no moving parts, magmeters, as they're called, are easy to maintain and offer good accuracy for most applications.

In essence, magnetic flowmeters measure flow via magnetic coils powered by either alternating current (AC) or direct current (DC). When the current powers the coils, a magnetic field is created in the area of the flowing liquid. When conductive liquid flows through a magnetic field, a voltage is generated that is directly proportional to the velocity of the fluid. The magmeter detects this voltage using electrodes that are typically positioned on either side of the pipe and computes flow velocity based on the amount of voltage present.

From Continuous AC to Pulsed DC

Magnetic flowmeters were first introduced for commercial use in Holland in 1952 by The Tobinmeter Company. Foxboro (www.foxboro.com) released magmeter technology in the United States in 1954. Today there are more than 50 suppliers of magnetic flowmeters.

First-generation magnetic flowmeters were powered by continuous alternating current, which is subject to noise that interferes with the proper reading of the meter. As a result, continuous AC meters need to be regularly calibrated against an on-site hydraulic zero to compensate for the presence of noise.

DC magmeters were invented mainly as a solution to the zero-calibration issues associated with continuous AC magmeters. These magmeters operate based on a pulsed direct current. When the current is turned on, a voltage is generated, showing the velocity of the flowing liquid, plus any noise. When the current is turned off, any remaining voltage is assumed to be noise.



Figure 1. EMCO Flow Systems' Unimag magnetic flowmeter is an example of a pulsed AC measurement system.

By subtracting this voltage measurement, the meter provides a flow measurement that accounts for the effects of noise.

In addition, pulsed DC magnetic flowmeters use less power and have a lower coil excitation frequency than continuous AC magmeters. They also typically cost less than continuous AC magnetic flowmeters, because their design does not have to minimize the effects of eddy currents. Pulsed DC magmeters are also easier to install and cost less to operate than continuous AC magnetic flowmeters.

Pulsed DC magmeters became popular in the 1980s. Today, over 85 percent of magnetic flowmeters sold worldwide use pulsed DC technology, and about 90 percent of magmeter suppliers offer DC technology. Even so, close to one-third of magnetic flowmeter suppliers still offer some type of AC magnetic flowmeter, and some suppliers have both continuous AC and pulsed DC magmeters in their product line.

To compensate for the lower signal strength of many DC magnetic flowmeters, suppliers have developed high-strength DC magmeters. These high-strength meters employ the on-off current technology of other pulsed DC meters, but they produce a stronger signal. This stronger signal results from a higher coil current. As a result, these high-strength meters can

handle high-noise applications, such as slurries and dirty liquids, better than other pulsed DC magmeters. Close to 25 percent of magnetic flowmeter suppliers today offer some type of high-strength pulsed DC magmeter.

Error Sources for Pulsed DC Meters

Even though pulsed DC magmeters dominate the market today, they still have their limitations, especially for slurries and other liquids containing solids. Two potential sources of error for pulsed DC magmeters are media noise and liner and electrode seal microporosity. Both of these sources of error can interfere with the integrity of the flowmeter signal and its ability to provide fast response with good accuracy.

There are multiple sources for media noise (see sidebar). These include entrained magnetically charged particles, solids impacting against the electrodes, low- and variable-media conductivity, and coated electrodes. Liner and electrode seal microporosity refers to the possibility that media molecules can migrate past the electrode seals or through the liner itself. Liner microporosity normally results from wear or large temperature differentials across the liner. Electrode microporosity emanates from minute liner and seal movements due to shock or variation in temperature or static pressure.

Pulsed AC Magmeters

While pulsed DC technology has a number of advantages, AC magmeters maintain advantages for certain applications. The strength of the current exciting the coils is

What Causes Media Noise?

- Electro-chemicals (e.g. Hydrogen ions +ve, hydroxyl ions -ve)
- Entrained magnetically charged particles
- Solids/particulate impact against electrodes (piezoelectric)
- Frictional effects against electrodes — fibers, etc. (triboelectric)
- Low and variable media conductivity
- Coated electrodes

Interchangeable Sensors:
Coils and electrodes can be easily replaced on site, without recalibration

Integrated Monitoring System:
Add pressure and multi-parameter sensors, and/or sampling ports

High Energy Design:
Problems with electrode fouling and low/variable media conductivity are eliminated

Totally Encapsulated Coils:
Sensors are unaffected by shock and vibration

No Liner Necessary:
Inaccuracy due to liner damage is eliminated

Integral Grounding Electrodes:
Grounding rings are normally unnecessary

Mathematically Designed, High Energy Magnetic Field:
Auto-zero correction plus high magnetizing current and energizing frequency ensure the highest possible signal-to-noise ratio. Two pairs of electrodes average irregular velocity profiles to provide true volumetric flow.

Figure 2. The Unimag's solid-state sensor is designed to eliminate liner and electrode seal microporosity and substantially reduce the effects of media noise.

typically less in DC magmeters than in AC magmeters. Consequently, AC magmeters have very good signal strength and rela-

tively high exciter frequency, which makes them suitable for slurries, pulps, and other noisy media. The combination of relatively

high exciter frequency, typically greater than 30 Hz, and exciter coil current, typically in the amps regime, significantly

Know The Flow...TM Sight Flow Indicators



Ask for our full line catalog of Sight Flow Indicators

JOHN C. ERNST  INC

Sparta, NJ E-mail: sales@johnernst.com
888-943-5000 Fax: 973-940-1620

www.sightflow.com

Circle 24 or Request Info Instantly at www.FlowControlNetwork.com

www.FlowControlNetwork.com

New, 4-20mA Transmitter Option Now Available on Model 220



Model 220 now provides a simple, low cost Loop Powered 8-28 Vdc two wire 4-20mA Transmitter using the same CSA, UL & ATEX rated sensor and explosion-proof housing used on the Model 220 with switches. The transmitter with an industrial type terminal strip is housed in a heavy-duty, cast aluminum housing. Wiring access is through a 1/2" NPT port. Accuracy is $\pm 2\%$ from 20% to 100% of full scale. Indicator accuracy is $\pm 2\%$ and is independent of the transmitter.

Additional Benefits:

- Indicating Transmitter is an option on all new 220 Models
- Safe working pressure to 4000 PSIG (275 bar)
- Full over-range protection
- Differential ranges available from 0-5 PSID to 100 PSID (0-0.35 to 7 bar)
- Weather-proof construction, 4 1/2" dials
- Corrosion resistant gauge front
- 5 Year Warranty

This unit is not yet listed for use in hazardous conditions.

For your application, go to our website

midwestinstrument.com

TOLL FREE

1-800-648-5778

SEND FOR INFORMATION

Mid-West Instrument

Mid-West Instrument

6500 Dobry Drive
Sterling Heights, MI 48314
Tel: 586-254-6500 Fax: 586-254-6509
E-Mail: sales@midwestinstrument.com

"Best Value in ΔP Instrumentation"

Circle 25 or Request Info Instantly at www.FlowControlNetwork.com

November 2006 27

improves signal quality by producing a strong, noise-free signal.

To counteract the disadvantages of continuous AC magmeters, while retaining some of the advantages of pulsed DC meters, some suppliers have introduced pulsed AC magnetic flowmeters. One such company is Siemens Energy & Automation (www.siemens.com), which sells the Transmag 2. Another company is EMCO Flow Systems (www.emcoflow.com), which manufactures the Unimag (Figure 1). EMCO refers to its technology as "pulsed hybrid."

This meter has an auto-zero feature and compensates for eddy currents, even at relatively high exciter frequencies up to 40 Hz. It has a strong exciter current in the amps regime, together with a typical exciter frequency of 40 Hz, making it a good choice for slurries, pulp, dirty, and clean media.


Another EMCO design features a magmeter without a liner. Electrodes, exciter, and reference coils are contained in a removable solid-state insulated sensor, positioned on either side of the flowtube. The large ratio of sensor diameter to flowtube diameter, as well as a plurality of sensors and a magnetizing current in the amps

regime, gives this design the same hydraulic accuracy as a conventionally designed continuous AC or a pulsed DC meter. For media with very thick coatings, optional extended electrodes are made long enough to protrude through the media coating. This solid-state sensor design eliminates liner and electrode seal microporosity and substantially reduces the effects of media noise (Figure 2).

Balancing the Benefits of AC vs. DC

Magnetic flowmeter technology has come a long way since 1952. Like other flowmeter types, magmeters have gone through a technological evolution, with many new innovations and improvements designed to compensate for previous disadvantages. Pulsed DC magmeters were introduced to counter the calibration and power issues of early-generation AC magmeters and have become the dominant technology. Now pulsed AC magmeters retain some of the benefits of both continuous AC and pulsed DC designs. However, no technology is perfect for all applications.

Despite all the advances made by magnetic flowmeter suppliers, no one yet has

figured out how to enable magmeters to effectively measure the flow of hydrocarbons, whose conductivity is usually very low. Magnetic flowmeters also cannot measure the flow of gas or steam. But suppliers have made advances in enabling magmeters to measure liquids with lower conductivity levels, and they have also significantly increased accuracy. Look for suppliers to continue to bring out new features and products as they deal with the unique challenges posed by magnetic flow measurement. 

Jesse Yoder, Ph.D., is a regular contributor to Flow Control magazine. He has been a leading analyst in the process control industry since 1986. He specializes in flowmeters and other field devices, including pressure, level, and temperature technologies. Dr. Yoder is currently president of Flow Research Inc., an analyst firm specializing in flow technology. He can be reached at jesse@flowresearch.com or 781 245-3200.

www.flowresearch.com

Fluid Handling Hose




Sanitary or Industrial Applications

- Rated for pressure, vacuum, & temperature extremes
- Silicone, polyurethane, PVC, TPR, nylon, fluoropolymers, PE, PP, latex, Hytrel®, Viton®, more
- Sizes from .012" to 4" I.D.
- Large inventory stocked
- Same-day shipment or JIT delivery
- Customer support to help select the right product for your application
- Heat-formed shapes, cut pieces, bonding, hose assemblies, coiling, custom sizes & colors



NEWAGE INDUSTRIES
FLUID TRANSFER SPECIALISTS®

ESOP Employee Owned
for Your Benefit

Call today

888-511-7183

fc@newageindustries.com

www.newageindustries.com/fc

NewAge and Fluid Transfer Specialists TMs NewAge Industries, Inc. • Hytrel reg. TM Dupont • Viton reg. TM Dupont Dow Elastomers